

## Ventilation grille Type AGS

CERTIFICATE

### Object of the test

TROX GmbH, Heinrich-Trox-Platz, 47504 Neukirchen-Vluyn, Germany, hereby confirm that the above mentioned products meet the requirements stipulated in the standards and guidelines below.

### European standards

EN 16798-3: 2017-11

### German standards

VDI 6022 Blatt 1: 2018-01

VDI 3803 Blatt 1: 2010-10

### Austrian standards

ÖNORM H 6021: 2016-08

### Swiss SWKI guidelines

VA104-01: 2006-04

For the purpose of this declaration of conformity a sample of each product type mentioned above was tested at the TROX GmbH factory at Siemensstraße 24, 47574 Goch, and related data sheets, technical documentation and test reports were appraised.

### Summary of the test result

The test of the above mentioned samples and the appraisal of the provided documents have shown that the hygiene requirements stipulated in the above mentioned standards and guidelines are met. This is to confirm that the products meet the hygiene requirements stipulated in the specified standards and guidelines.

Neukirchen-Vluyn, 11.09.2018



Dipl.-Ing. Dirk Scherder

VDI-certified specialist engineer RLQ



Dipl.-Ing. Jan Heymann

Manager Quality Systems