



# Control component

BUSNF







# Control component with static transducer and separate spring return actuator for VAV terminal units

Universal device for use with VAV terminal units



- Controller and static differential pressure transducer in one casing
- Separate actuator with spring return for safety positions
- Use in ventilation and air conditioning systems, with clean and contaminated air
- Suitable for constant and variable volume flow rates
- Activation of override controls via external wiring
- Volume flow rates q<sub>vmin</sub> and q<sub>vmax</sub> are set in the factory and saved in the controller
- Modification of operating parameters by PC software as well as smartphone and tablet app (TROX FlowCheck app)
- Service access for PC configuration software
- Smartphone access via NFC interface and Bluetooth
- Setpoint value settings, override controls and parameter adjustment via analogue interface or bus communication
- High data transparency through standardised bus communication MP-Bus, Modbus RTU or BACnet MS/TP



X-AIRCONTROL zone module MP-bus

# **TRO**<sup>®</sup>теснык

General information Function Specification text Order code

### General information

Product data sheet

Variants

Technical data

Product details

Explanation

2

3

4

5

### Application

- All-in-one control engineering device for VAV terminal units
- Static differential pressure transducer and control electronics in one casing
- Separate actuator with spring return
- Safe position can be defined upon failure of the supply voltage or wire breakage in the order code: NC = damper closed, NO = damper in OPEN position
- · For use with clean and contaminated air
- Choice of various control options based on setpoint value default setting
- Volume flow rate control is based on setpoint values received from room temperature controller, central BMS, air quality controller or other devices as an analogue signal or via communication interface
- Override controls for activating q<sub>vmin</sub>, q<sub>vmax</sub>, shut-off, OPEN position via MP-Bus data points or Modbus/BACnet register or switch/relay possible
- The volume flow rate actual value is available as a network data point or as a linear voltage signal
- The damper blade position is available as a network data point
- Use the TROX FlowCheck app and PC tool to configure the controller and the communication parameters

### **Control strategy**

- The volume flow controller works independent of the duct pressure
- Differential pressure fluctuations do not result in permanent volume flow rate changes
- To prevent the control from becoming unstable, a dead band is allowed within which the damper blade does not move
- The flow rate range for the controller is set in the factory
  - q<sub>vmin</sub>: minimum volume flow rate
  - q<sub>vmax</sub>: maximum volume flow rate
- Operating parameters are set in the factory according to the order code

### Interface

Analogue interface

- Analogue interface with adjustable signal voltage range
- Analogue signal for volume flow rate setpoint
- Analogue signal for volume flow rate actual value
- Digital communication interface (bus)
- MP bus
- Modbus RTU, RS-485
- BACnet MS/TP, RS-485
- Data points, see bus lists
- Hybrid mode

Mixed mode of analogue and digital interface
Factory setting

- Setpoint value default setting via analogue interface
- Actual value output via analogue interface and Modbus communication interface

### **Operating modes**

Variable operation (V)

- Setpoint value setting via analogue signal, Modbus, BACnet or MP-Bus: operating range corresponds to q<sub>vmin</sub> – q<sub>vmax</sub>
   Constant value mode (F)
- A setpoint signal is not required, setpoint value corresponds to q<sub>vmin</sub>

### **Operating parameters**

- The flow rate range for the controller is set in the factory
  - q<sub>vmin</sub>: minimum volume flow rate
  - $q_{vmax}$ : maximum volume flow rate
- $q_{vmin} = 0 100$  % of the nominal volume flow rate  $q_{vnom}$  adjustable
- q<sub>vmax</sub> = 20 100 % of the nominal volume flow rate q<sub>vnom</sub> adjustable

### Signal voltage ranges

- 0 10 V DC
- 2 10 V DC

### Parts and characteristics

- Transducer for static measurement principle
- Separate actuator with simple connection plug
- Plug-in terminals for power and bus cables, with cover
- Socket for the actuator
- NFC and service interfaces
- · Crank handle for manual winding of the spring return actuator
- Release button to allow for manual operation
- Indicator lights for displaying the operating mode
- Addressing button to confirm the addressing request of an MP master (only in MP-Bus mode)
- Controller casing prepared with 4 openings for threaded connections, 2 cable glands M16x1.5 for connecting cable in the supply package

### Construction

BUSNF with actuator LF24-VST for:

TVR, TVZ, TVA, TVRK up to NW 250

BUSNF with actuator NF24A-VST for:

- TVJ, TZ-Silenzio, TA-Silenzio all dimensions
- TVR, TVZ, TVA, TVRK for NW 315 400
- TVT up to dimension 1000 × 300 or 800 × 400

### Commissioning

- Due to the volume flow rates set in the factory, always ensure that the control units are only installed in the specified locations
- Modbus/BACnet/MP bus interface: additional commissioning steps required
- Operating parameters can be adjusted using the TROX FlowCheck app

### Useful additions

2/33

- TROX FlowCheck app for Android and iOS
- Bluetooth-to-NFC converter ZIP-BT-NFC
- Belimo PC-Tool software
- X-AIRCONTROL zone modules for room control

# 

### BUSNF

6

7

23

33



### **Function**


A closed control circuit for regulation of the volume flow rate, i.e. measuring - comparing - adjusting, is characteristic of air terminal units.

The volume flow rate is recorded by measuring a differential pressure (effective pressure). This is done via a differential pressure transducer converts the effective pressure into a voltage signal. The volume flow rate actual value is available as a voltage signal. The factory setting is such that an actual output signal of 10 V DC always corresponds to the nominal volume flow rate  $(q_{vnom})$ . The volume flow rate setpoint value is specified by a higher-level via the order code.

controller (e.g. room temperature controller, air quality controller, central BMS). Variable volume flow control results in a value between  $q_{vmax}$  and  $q_{vmax}$ . It is possible to override the room temperature control by override control, e.g. by a complete shutoff of the duct.

The controller compares the volume flow rate setpoint value to the actual value and controls the external actuator accordingly to the system deviation. If the supply voltage is interrupted or there is a wire breakage, the spring return actuator moves to the OPEN (NO) or CLOSED (NC) position that was set at the factory via the order code.

### Principle of operation Universal controller: TVR, TVJ, TVT, TZ-/TA-Silenzio, TVZ, TVA, TVRK



① Differential pressure transducer

Actuator

③ Volume flow controller

④ Setpoint value signal





### Specification text

This specification text describes the general properties of the product.

### Category

Universal controller for volume flow rate with safe position

### Application

- Control of a constant or variable volume flow rate setpoint
- Electronic controller for connecting a controlled variable and tapping an actual value signal
- The actual value signal relates to the nominal volume flow rate such that commissioning and subsequent adjustment are simplified
- Stand-alone operation or integration in central building management system

### Area of application

 Effective pressure transducer for static pressure measurements in ventilation and air conditioning systems with clean and contaminated air

### Actuator

 Spring return actuator for defined safe position of the damper blade in case of power failure. Run time 120 s for 90°; run time spring return < 20 s for 90°</li>

### Installation orientation

Either direction

### Connection

Pluggable connection terminals; no additional terminal box required

### Supply voltage

24 V AC/DC

### Interface/signalling

- Analogue signal • 0 – 10 V DC or 2 – 10 V DC,
- Bus interface
- MP bus

- Modbus RTU
- BACnet MS/TP

### Interface information

Analogue:

- Volume flow rate setpoint and actual value Bus interface:
- · Volume flow rate setpoint and actual value
- Damper blade position
- Fault status

### System connections

MP-Bus for optional extensions

- Suitable for TROX X-AIRCONTROL zone module X-AIR-ZMO-MP
- Gateways for Modbus, BACnet, KNX, e.g. Belimo UK24EIB
- Fan optimiser, e.g. Belimo COU24-A-MP

Modbus RTU for optional extensions

 Suitable for TROX X-AIRCONTROL zone module X-AIR-ZMO-MOD, e.g. in conjunction with X-SENS-SPLITTER

### **Special functions**

 Activation q<sub>vmin</sub>, q<sub>vmax</sub>, Closed, Open, Control Stop by means of external switch contacts/wiring or bus communication

### Parameter setting

- Parameters specific to VAV terminal unit set at the factory
- Operating values q<sub>vmin</sub>, q<sub>vmax</sub> factory set
- Signal characteristic factory set

Subsequent adjustment

- Via TROX FlowCheck app (NFC or Bluetooth with optional adapter)
- Via PC software

### **Factory condition**

- · Electronic controller factory-mounted on the terminal unit
- Factory parameter settings
- · Functional test under air; certified with sticker



### Order code

### Control component BUSNF (shown together with TVR as an example)

	- D -	• P1 •	- /	200	/ D2 /	BUSNF	-/V0/5	00 – 1200 [m³	/h] / NO
1	2	3	4	5	6	7	9 10	11	12

1 Type TVR VAV terminal unit

#### 2 Acoustic cladding

No entry: none D With acoustic cladding

### **3 Material**

No entry: galvanised sheet steel P1 Powder-coated RAL 7001 (silver grey) A2 Stainless steel construction

#### **4 Duct connection**

No entry: push-fit, suitable for ducts according to EN 1506; with groove for optional lip seal **FL** Flanges both ends (not with TVR-D-P1)

### 5 Nominal size [mm] 100, 125, 160, 200, 250, 315, 400

### 6 Accessories

No entry: without accessories D2 Double lip seal both ends (push-fit only) G2 Matching flanges for both ends (only with FL)

### 7 Attachments (control component)

**BUSNF** Universal volume flow rate controller with static transducer and separate spring return actuator

### 9 Operating mode

F Constant value mode, one setpoint value (no external switch contact)V Variable operation (adjustable setpoint value range)

#### 10 Signal voltage range

For the actual and setpoint value signals 0 0 - 10 V DC 2 2 - 10 V DC

### 11 Operating values for factory setting

Volume flow rate [m<sup>3</sup>/h or l/s]

Depending on operating mode F:  $q_{vconst}$ V:  $q_{vmin} - q_{vmax}$ 

### 12 Damper blade position

Only with spring return actuators **NO** Power off to open (Normally Open) **NC** Power off to close (Normally Closed)

### Order example: TVR-D-P1/200/D2/BUSNF/V0/500-1200[m3/h]/NO

Туре	TVR
Acoustic cladding	With acoustic cladding
Material	Powder-coated RAL 7001 (silver grey)
Duct connection	Push-fit, suitable for ducts according to EN 1506; with groove for optional lip seal
Nominal size [mm]	200
Accessories	Double lip seal both ends
Attachments (control component)	BUSNF – Universal controller with static transducer and separate spring return actuator for room pressure control
Operating mode	Variable operation
Signal voltage range	2 – 10 V DC
Operating values for factory setting	500 – 1200 [m³/h]
Damper blade position	Power off to open (Normally Open)






### Variants

#### Universal controller, type VRU-M1-M/B TR



- ① Adaptation key
- ② Actuator connection socket
- ③ NFC interface
- ④ Dummy cover (not in use)
- ⑤ Cable glands (separate supply and control)
- 6 Fixing holes
- Connection for effective pressure

#### Universal controller, type VRU-\*\*\*-M/B TR (terminal cover opened)



- Yellow status LED; address confirmation (only with MP-Bus operation)
- ② Magnetic holder for ZIP-BT-NFC
- ③ Service socket
- ④ Pluggable terminal strips
- ⑤ Cover fixing (safety cable)

#### Actuator with spring return NF24A-VST TR



- ① Axle support
- ② Actuator total
- ③ Plug connection for the controller
- ④ Mechanical end stop for rotation angle
- ⑤ Direction of rotation of spring return (clockwise here)
- $\textcircled{\sc blue}$  Holder for crank handle for manual winding (locking via abrupt
- change of direction of rotation)
- ⑦ Connecting cable



- ① Axle support
- Actuator total
- ③ Position lock spring return (e.g. after manual winding using crank handle)
- ④ Socket for the crank handle
- ⑤ Connecting cable
- ⑥ Plug connection for the controller
- ⑦ No function
- ⑧ Mechanical end stop for rotation angle

## TRO

#### Actuator with spring return LF24-VST TR



### **Technical data**

### Universal controller for VAV terminal units

Order code detail Part number	Туре	Part number	Туре	VAV terminal units

1

TVR, TVZ, TVA, TVRK up to NW 250

2

TVR, TVZ, TVA, TVRK from NW 315

TVJ

TVT up to dimension 1000 × 300 or 800 × 400



### Universal controller, type VRU-M1-M/B TR



### Universal controller, type VRU-M1-M/B TR

Type of measurement/installation orientation	static measuring principle, position-independent
Nominal voltage	AC/DC 24 V
Rated voltage frequency	50/60 Hz
Functional range	AC 19.2 – 28.8 V/DC 21.6 – 28.8 V
Power consumption (when running/when idle)	1.5 W
Power requirement dimensioning	2 VA plus connected VST drive
Power consumption dimensioning note	I <sub>max</sub> 20 A @ 5 ms
Drive connection	AC/DC supply through controller, PP-Link VST drive
Bus connection	Modbus RTU*, BACnet MS/TP, MP-Bus
	Baud rate: 9600, 19200, <b>38400</b> *, 76800, 115200;
	Address: 1*,2.3 – 247;
Modbus RTU communication parameters to be set	Parity: <b>1-8-N-2</b> *, 1-8-N-1, 1-8-E-1, 1-8-O-1;
	Number of nodes: maximum 32 (without repeater)
	Terminal resistor: 120 $\Omega$ , integral, can be activated
	Baud rate: 9600, 19200, <b>38400</b> *, 76800, 115200;
BACnet MS/TP communication parameters to be set	Address: 1*,2.3 – 127;
DACHELMS/TT Communication parameters to be set	Number of nodes: maximum 32 (without repeater)
	Terminating resistor: 120 $\Omega$ ; integrated, switchable
Addressing	Required on site: by smartphone app
Setpoint value signal input (analogue optional)	0 - 10 V DC, 2 - 10 V DC
	Input resistance 100 kΩ
Actual value signal output	0 - 10 V, 2 - 10 V, maximum 0.5 mA
Protection class IEC/EN	III (Protective extra-low voltage)
Protection level	IP 42
EMC	CE according to 2014/30/EU
Weight	0.3 kg

\* Factory setting.



### Actuator with spring return NF24A-VST TR



### Actuator with spring return NF24A-VST TR

Power supply	from the controller
Power consumption – when running	5 W
Power requirement dimensioning	8 VA
Self-consumption (idle state)	2.5 W
Torque	10 Nm
Run time for 90°	120 s/90°
Running time emergency control function	< 20 s/90°
Setpoint value signal input	from the controller
IEC protection class	III (Protective extra-low voltage)
Protection level	IP 54
EMC	EMC to 2014/30/EU
Weight	2.3 kg
Manual adjustment	by hand crank and locking switch





### Meaning of the green status LED/push button (applies to all VRU control components)

Meaning
Power supply ok - Normal operation
in operation - status message pending*
Trigger rotation angle adaptation, then normal operation

\* **Status message pending:** signals a pending status message, whereby the type of fault is not specified. For a concrete evaluation of this collective fault message, a query must be made using service tools or the bus interface:

- Belimo Assistant app, TROX FlowCheck app or Belimo PC-Tool software
- MP-Bus command, Modbus register, BACnet object

### Meaning of the yellow status LED/push button (applies to all VRU control components)

LED/push button (yellow)	Meaning
blinking	MP-Addressing
at the press of the button	Confirmation of addressing

### Commissioning

- As the volume flow rates are factory set, the terminal units have to be installed at the specified locations
- · After installation and wiring, the controller is ready for operation via the analogue interface
- Comply with the volume flow rate control ranges of the VAV terminal units; do not set a volume flow rate lower than the minimum flow rate
- · Only briefly remove the protective cap of the control component during wiring

For bus operation, further commissioning steps are required depending on the required integration of the control component into the local network:

### For operation with Modbus interface

- Switching the setpoint to bus with the service tool
- Bus protocol is already set in the factory from Modbus RTU; no adjustment required
- · Adjust Modbus participant address and communication settings

### For operation with BACnet interface

- Switching the setpoint to bus with the service tool
- Switch bus protocol to BACnet MS/TP with service tool
- Adjust BACnet subscriber address and communication settings

### For operation with MP-Bus interface

- Switching the setpoint to bus with the service tool
- Switch bus protocol to MP-Bus with service tool
- Adjusting the MP-Bus subscriber address and communication settings
- For operation with MP-Bus interface in existing systems as a replacement for VRP-M controllers: Activation of VRP-M compatibility mode required



Function/parameter setting	TROX FlowCheck app	PC-Tool <sup>1</sup>	ZTH-EU
Setting of q <sub>vmin</sub> , q <sub>vmax</sub>	R, W <sup>2</sup>	R, W	R, W
Signal voltage range setting 0 – 10 V or 2 – 10 V DC for analogue interface	R, W <sup>2</sup>	R, W	-
Setpoint value default setting via analogue connection or bus (Modbus, BACnet or MP bus)	R, W <sup>2</sup>	R, W	-
Modbus, BACnet settings (address, communication parameters)	R, W <sup>2</sup>	R, W	_
MP-Bus settings (address)	R, W <sup>2</sup>	R, W	-
Execute override controls (test function)	yes <sup>3</sup>	yes	-
Trend display	yes <sup>3</sup>	yes	-

R, W = function is readable and writable

- = Function is not available for the service tool

<sup>1</sup> Requires interface converter, e.g. setting devices ZTH-EU

<sup>2</sup> Function/parameterisation is possible without connecting the controller to supply voltage

<sup>3</sup> Function/parameterisation only in conjunction with ZIP-BT-NFC and connected power supply to the controller

For the proper use of the service tools, they should always be kept up to date with the latest software version. Information on current versions/updates for PC-Tool software and setting device ZTH-EU on the Belimo homepage www.belimo.com.

Minimum versions for ZTH-EU firmware: V 2.09.0004





Number	Register Address	Description	Range Enumeration	Unit	Scaling	Access
1	0	Setpoint value between $q_{vmin}/\Delta p_{min}$ (reg. address 105) and $q_{vmax}/\Delta p_{max}$ (reg. address 106) (*1) (*2) (*3) (*4)	0 – 10,000 Factory setting: 0	%	0.01	[R / W]
2	1	Override control Overwrites the setpoint value with override control	0: None 1: OPEN 2: CLOSED 3: q <sub>vmin</sub> /Δp <sub>min</sub> 5: q <sub>vmax</sub> /Δp <sub>max</sub> Factory setting: None	-	_	[R / W]
3	2	Command triggering Triggering of functions for service and test purposes. Command ends automatically with 0	0: None 1: Adapting 3: Synchronisation Factory setting: None	-	_	[R / W]
4	3	Type of actuator (*5)	0: Actuator not connected/not known 1: Actuator Air/Water with/without safety function 2: Volume flow controller VAV/EPIV 3: Fire damper 4: Energy Valve 5: 6way EPIV	-	-	[R]
5	4	Current damper blade position acc. to mechanical limits (*5)	0 – 10,000	%	0.01	[R]
6	5	Blade angle acc. to angle range (*5)	0 – 9,600	0	0.01	[R]
7	6	Relative volume flow rate related to $q_{vnom}$ (reg. address 110) (*6)	0 – 15,000	%	0.01	[R]
8	7	Absolute volume flow rate (*6)	0 – q <sub>vnom</sub>	m³/h	1	[R]
9	8	Sensor value (voltage, resistance, switch) Value dependent on the setting of the sensor type (reg. address 107)	0 – 65,535	mV, Ω, 0/1	0.1	[R]
10	9	-	-	_	-	[-]
11	10	Absolute volume flow rate in selected volume flow unit acc. to (reg. address 117) (Low word) < 16 of 32 bit (*6)	0 – 500,000,000	UnitSel	0.001	[R]
12	11	Absolute volume flow rate in selected volume flow unit acc. to (reg. address 117) (High word) > 16 of 32 bit (*6)	0 – 500,000,000	UnitSel	0.001	[R]
13	12	Analogue setpoint value	0 – 10,000	%	0.01	[R]
	TECH	I. Contraction of the second se	I	I.	PD-01/20	I



Number	Register Address	Description	Range Enumeration	Unit	Scaling	Access
		Shows the setpoint value in % with analogue control input signal. Active if reg. address 118 = 0 (analogue)				
51		Relative differential pressure According to application case as per (reg. address 128)	0 – 20,000	%	0.01	[R]
52		Absolute differential pressure	-1,000 – 15,000	[Pa]	0.1	[R]
53		-	-	_	-	[-]
54		Absolute differential pressure in selected unit (reg. address 145) (Low word) < 16 of 32 bit	-10,000,000 – 100,000,000	UnitSel	0.001	[R]
55		Absolute differential pressure in selected unit as per (reg. address 145) (High word) > 16 of 32 bit	-10,000,000 – 100,000,000	UnitSel	0.001	[R]
100	99	Bus terminal resistor Indicates whether the terminal resistor (120 $\Omega$ ) is active or deactivated. Can only be set using service tools.	0: Not active 1: Active Factory setting: Not active	_	_	[R]
101	100	Serial number, part 1 Example: 00839-31324-064-008 1 <sup>st</sup> part: 00839 2 <sup>st</sup> part: 31324 3 <sup>st</sup> part: 008	-	-	-	[R]
102	101	Serial number, part 2	_	-	-	[R]
103	102	Serial number, part 3	-	-	-	[R]
104	103	Firmware version Example: 101, version 01.01.	-	-	-	[R]
105	104	Malfunctions and service information – automatic reset if status has ceased	Bit 0: – Bit 1: Mechanical travel too high Bit2: Actuator cannot be moved (e.g. mechanical overload) Bit 3: – Bit 4: Error of dP sensor Bit 5: Return air flow detected Bit 6: Volume flow rate too low Bit 7: Flow rate in closed position Bit 8: Internal activity (e.g. test run, adaptation) Bit9: Gear release active Bit10: Bus monitoring triggered Bit 11: Actuator not suitable for application Bit 12: Pressure sensor incorrectly connected Bit 13: Pressure sensor not reached Bit 14: Error in dP sensor outside of measuring range	_	_	[R]
106	105	Setting work areas $q_{vmin}/\Delta p_{min}$ Requirements: $q_{vmin}/\Delta p_{min} < q_{vmax}/\Delta p_{max}$ Vmax in the area 0 – 100 % of $q_{vnom}/\Delta p_{nominal}$	$0-q_{vmax}/\Delta p_{max}$	%	0.01	[R / W*]
107	106	Setting work areas q <sub>νmax</sub> /Δp <sub>max</sub> Requirements: q <sub>νmax</sub> /Δp <sub>max</sub> < q <sub>νmin</sub> /Δp <sub>min</sub>	2,000-10,000	%	0.01	[R / W*]

# **TRO**<sup>®</sup>теснык



BUSNF

Number	Register Address	Description	Range Enumeration	Unit	Scaling	Access
		Vmax in the area 20 – 100 % of $q_{vnom}$ /				
		Δp <sub>nominal</sub>				
108	107	Type of sensor If reg. address 118 = 0 (analogue), then reg. address 107 = 1 (active) for mV	0: None 1: Active 2: Passive 3: – 4: Switch Factory setting: None	_	-	[R / W*]
		Bus timeout monitoring				
109	108	If there is a bus timeout, the actuator moves into a position specified here. The position is mech. limited, $q_{vmin}$ / $\Delta p_{min}$ and $q_{vmax}/\Delta p_{max}$ have no impact. Release if no change takes place in reg. address 1 or reg. address 2 in the specified time for reg. address 109. Display of release in reg. address 104. In hybrid mode, bus timeout activation is deactivated.	0 – 10,000 Factory setting: 0	%	0.01	[R / W*]
		Bus timeout time: acc. to reg. address 109				
110	109	Time until release bus timeout monitoring If reg. 108 $\neq$ 0, then the initial automatic status is reg. 108 = 120 s.	0 – 3,600 0: Inactive Factory setting: Deactivated	s	1	[R / W*]
113	112	Nominal volume flow rate in selected volume flow unit acc. (reg. address 117)	0 – 60,000,000	UnitSel	0.001	[R]
		(Low word) < 16 of 32 bit				
114	113	Nominal volume flow rate in selected volume flow unit acc. (reg. address 117)	0 – 60,000,000	UnitSel	0.001	[R]
		(High word) > 16 of 32 bit				
115	114	-	-	-	-	[-]
116 117	115 116	Control mode	<ul> <li>O: Position control (open loop)</li> <li>1: Volume flow control</li> <li>Factory setting: Volume flow control</li> </ul>	-	_	[-] [R]
118	117	Unit selection – Unit selection for reg. address 11 and 12	0: - 1: m <sup>3</sup> /h 2: l/s 3: - 4: - 5: - 6: cfm	-	_	[R / W*]
119	118	Setpoint value setting If reg. address 118 = 0 (analogue), then reg. address 12 = active. If reg. address 118 = 1 (Bus), then reg. address 1 = active.	0: Analogue (0 – 10 V, 2 – 10 V) 1: Bus (Modbus, BACnet, MP-Bus) Factory setting: Analogue	_	-	[R / W*]
<b>TRO</b>	TECH	INIK	14 / 33		PD-01/202	24 - DE/e



Number	Register Address	Description	Range Enumeration	Unit	Scaling	Access
120		Pressure operating mode Only for VRU-M1R-M/B TR.	0: Negative pressure 1: Positive pressure	_	-	[R / W*]
121		-	_	-	-	[-]
122		_	_	_	-	[-]
123		-	-	_	-	[-]
124		Room pressure cascade release Only available if reg. address 124 = 0 (volume flow control) or 2 (room pressure control).	0: Inactive 1: Active 2: Active fast (only for VRU-M1R-M/B TR)	-	_	[R]
125		Applications	0: Volume flow control 1: Pressure control 2: Room pressure control 3: Flow measurement	-	-	[R]
126		Unit height	0 – 3,000 Factory setting: 0	m	1	[R / W*]
127		Nominal differential pressure in the selected unit as per (reg. address 145) More info in (reg. address 128)	D3: 0 – 50000 M1: 0 – 60000 M1R: 0 – 60000	UnitSel	_	[R]
128			_	_	_	[-]
129		Nominal differential pressure in Pa If reg. address 124 = 0 (volume flow control), then reg. address 110 as q <sub>vnom</sub> . If reg. address 124 = 1 (differential pressure control) or 2 (room pressure control), then the maximum is defined by the diff. pressure.	D3: 0 – 500 M1: 0 – 600 M1R: 0 – 750	Pa	0.1	[R]
146		Selection of the pressure unit The selected unit is displayed in (reg. address 126).	0: Pascal 1: – 2: Water column Factory setting: Pascal	_	_	[R / W*]

[R] = Read-only access to register

[R/W] = Register readable and writable

[R/W\*] = Register readable and writeable with restrictions; all writeable registers from 100 are persistent (stored in the EEPROM), regular or cyclical writing must be avoided.

(\*1) If reg. addr. 118 = 1 (bus), then reg. addr. 0 = active

(\*2) If reg. addr. 124 = 0 (flow rate control), then reg. addr. 0 = flow rate

(\*3) If reg. addr. 124 = 0 (volume flow control) and reg. addr. 116 = 0 (position control), then reg. addr. = damper blade position

(\*4) If reg. addr. 124 = 1 (differential pressure control) or 2 (room pressure control), then reg. addr. = pressure

(\*5) If reg. addr. 124 = 2 (room pressure control) or 3 (volume flow measurement), then reg. addr. = deactivate 65.535

(\*6) If reg. addr. 124 = 1 (differential pressure control) or 2 (room pressure control), then reg. addr. = deactivate 65.535

# 



### BACnet MS/TP - Protocol Implementation Conformance Statement - PICS (General information)

ment - PICS (General Information)
2020-06-11
TROX GmbH
329
VRU-D3-BAC, VRU-M1-BAC, VRU-M1R-BAC
VRU - BAC
01.02.0001
10.02.0000
12
Controller for VAV/CAV and pressure applications
BACnet Application Specific Controller (B-ASC)
Data Sharing – ReadProperty-B (DS-RP-B) Data Sharing – ReadPropertyMultiple-B (DS-RPM-B) Data Sharing – WriteProperty-B (DS-WP-B) Data Sharing – WritePropertyMultiple-B (DS-WPM-B) Data Sharing – COV-B (DS-COV-B) Device Management – DynamicDeviceBinding-B (DM-DDB-B) Device Management – DynamicObjectBinding-B (DM-DOB-B) Device Management – DeviceCommunicationControl-B (DM- DCC-B)
No
MS/TP master, baud rates: 9600, 19200, 38400, 76800, 115200
No static device binding supported
None
ISO 10646 (UTF-8)
None
Non-secure device



Object type	Optional properties	Writeable properties
Analog Input [AI]	Description COV Increment	COV Increment
Analog Output [AO]	Description COV Increment	Present Value COV Increment Relinquish Default
Analog Value [AV]	Description COV Increment	Present Value COV Increment
Binary Input [BI]	Description Active Text Inactive Text	
Device	Description Location Active COV Subscriptions Max Master Max Info Frames Profile Name	Object identifier Object Name Location Description APDU Timeout (1000 – 60000) Number Of APDU Retries (0 – 10) Max Master (1 – 127) Max Info Frames (1 – 255)
Multi-state Input [MI]	Description State Text	
Multi-state Output [MO]	Description State Text	Present Value Relinquish Default
Multi-state Value [MV]	Description State Text	Present Value (if marked)

Editing of services

- The unit does not support the services "Create object" and "Delete object".
- The specified maximum length of writable strings is based on single-byte characters.
- 1. Object name 32 characters
- 2. Location 64 characters
- 3. Description 64 characters
- The unit supports DeviceCommunicationControl services, no password required.
- A maximum of 6 active COV subscriptions with a runtime of 1 28800 s (maximum 8 h) are supported.



### Communication interface BACnet MS/TP - BACnet objects

Object Name	Object Type	Description	Values	COV Increment	Access
	Device	Description	0 - 4,194,302		
Device	[Inst.No]		Factory setting: 1	-	WR
RelPos	AI[1]	Damper blade position in % <u>Status flags:</u> (*1), (*2)	0 – 100	0.01 – 100 Factory setting: 1	RD
AbsPos	AI[2]	Absolute position in ° Angular position corresponding to the entire rotation range. <u>Status flags:</u> (*1), (*2)	0 – max. angle	0.01 – 90 Factory setting: 1	RD
SpAnalogue	AI[6]	Analogue setpoint value in % Shows the analogue setpoint value according to the selected application flow rate, pressure, damper blade position as per ApplicationSel MV[2]. If setpoint value setting in SpSource MV[122] = 1 (analogue), then SpAnalog Al[6] = active. The analogue setpoint value is limited by Min AV[97] and Max AV[98]. <u>Status flags: (*1), (*3)</u>	0 – 100	0.01 – 100 Factory setting: 1	RD
RelDeltaP	AI[9]	Relative differential pressure in % with respect to DeltaPnom_Pa AV[122]	0 – 150	0.01 – 150 Factory setting: 1	RD
RelFlow	AI[10]	Relative volume flow rate in % related to Vnom_m3h AV[112] <u>Status flags:</u> (*4)	0 – 150	0.01 – 150 Factory setting: 1	RD
AbsFlow_m3h	AI[12]	Absolute volume flow rate in m <sup>3</sup> /h Status flags: (*4)	0 – 60,000	1 – 60,000 Factory setting: 10	RD
DeltaP_UnitSel	AI[18]	Absolute differential pressure in selected unit as per UnitSelPressure MV[127]	-10,000 – 100,000	0.001 – 100,000 Factory setting: 1	RD
AbsFlow_UnitSel	AI[19]	Absolute volume flow rate in selected unit as per UnitSelAirFlow MV[121] <u>Status flags:</u> (*4)	0 – 500,000	0.01 – 500,000 Factory setting: 1	RD
Sens1Analogue	AI[20]	Sensor 1 as analogue value If Sensor1Type MV[220] = 2 (active), then display = analogue value in 0 – 10 V. If Sensor1Type MV[220] = 3 (passive), then display = resistance value. If RmPCascade MV[10] = 2 (enabled) or 3 (quickly enabled), then the sensor input is not	0 – 65535	0.01 – 1000 Factory setting: 1	RD

# **TRO**<sup>®</sup>теснык



Object Name	Object Type	Description	Values	COV Increment	Access
		available.			
		<u>Status flags:</u> (*5)			
DeltaP_Pa	AI[29]	Absolute differential pressure in Pa	0 – 600	0.01 – 600 Factory setting: 10	RD
		Relative setpoint value in %			
SpRel	AO[1]	The rel. setpoint value depends on the application (flow rate/pressure/ damper blade position). If SpSource MV[122] = 2 (bus), then SpRel AO[1] = active. The analogue setpoint value is limited by Min AV[97] and Max AV[98].	0 – 100 Factory setting: 0	0.01 – 100 Factory setting: 1	С
		<u>Status flags:</u> (*1), (*2) Minimum setpoint value in % (q <sub>vmin</sub> /			
Min	AV[97]	$ \begin{array}{l} \mbox{P_min} \mbox{Wininfacture setpoint value in 7.6 } (q_{vmin} \mbox{P_min}) \\ \mbox{Requirement:} \\ \mbox{q_{vmin}} \slash \Delta p_{min} < \mbox{q_{vmax}} \slash \Delta p_{max} \\ \mbox{q_{vmin}} \slash \Delta p_{min} \mbox{ in the range 0 - 100 & q_{vnom}} \end{array} $	0 – q <sub>vmax</sub> /Δp <sub>max</sub>	0.01 – 100 Factory setting: 1	WR
		Maximum setpoint value in % ( $q_{vmax}$ /			
Max	AV[98]	$P_{max}$ ) Requirement: $q_{vmax}/\Delta p_{max} > q_{vmin}/\Delta p_{min}$ $q_{vmax}/P_{max}$ in the range 20 - 100 % of $q_{vnon}/P_{nom}$	q <sub>vmin</sub> /Δp – 100	0.01 – 100 Factory setting: 1	WR
Vnom_m3h	AV[112]	Nominal volume flow rate in m³/h	0 – 50,000	0.01 – 50,000 Factory setting: 1	RD
Vnom_UnitSel	AV[119]	Nominal volume flow rate in selected unit as per UnitSel MV[121]	0 – 250,000	0.01 – 1,000: Factory setting: 1	RD
SystemAltitude	AV[120]	System altitude in metres above sea level	0 – 3,000	1 – 3,000 Factory setting: 10	WR
DeltaPnom_Pa	AV[122]	Nominal differential pressure in Pa The nominal differential pressure depends on the selected pressure sensor (D3, M1, M1R). Depending on the selected application, the nominal differential pressure serves as dp@Vnom or as the maximum pressure limitation If ApplicationSel MV[2] = 1 (flow control), then display = nominal differential pressure If ApplicationSel MV[2] = 2 (pressure control) or 3 (room pressure control), then display = max. pressure limitation	D3: 0 – 500 M1: 0 – 600 M1R: 0 – 75	1 – 600 Factory setting: 1	RD

# TRO



		NI	
0	UG	IN	

Object Name	Object Type	Description	Values	COV Increment	Access
DeltaPnom_UnitSel	AV[129]	Nominal differential pressure in selected unit as per UnitSelPressure MV[127] More infos: see AV[122].		0.01 – 1000 Factory setting: 1	RD
BusWatchdog	AV[130]	Time until the release bus timeout monitoring in s If BusWatchdog AV[130] ≠ 0, then monitoring of SpRel AO[1] and override MO[1] for change. If changes in SpRel AO[1] and override MO[1], then reset the bus timeout monitoring. If SpSource MV[122] = 1 (analogue), then BusWatchdog AV[130] only takes account of override MO[1].	0 – 3600 s Factory setting: 0 (bus timeout monitoring deactivated)	0.01 – 1000 Factory setting: 1	WR
Sens1Switch	BI[20]	Switch status of the switch at the sensor input If SenType MV[220] = 5 (switch), then Sens1Switch BI[20] = active. <u>Status flags:</u> (*6)	0: Inactive 1: Active	_	RD
BusTermination	BI[99]	Terminal resistor Shows whether the terminal resistor (120 $\Omega$ ) has been activated via the service tools.	0: Deactivated 1: Activated	-	RD
SummaryStatus	BI[101]	Condensed status Groups together the status of the objects: "StatusSensor" MI[103] "StatusFlow" MI[104] "StatusActuator" MI[106] "StatusPressure" MI[109] "StatusDevice" MI[110]	Not equal to 1: OK 1: Not OK	_	RD
RmPCasacade	MV [10]	Room pressure cascade If RmPCascade MV[10] = 2 (active) or 3 (active fast), then sensor1 is the input for the room cascade (0 – 10 V). If ApplicationSel MV[2] =1 (volume flow control) or 3 (room pressure control), then RmPCascade MV [10] = active. <u>Status flags:</u> (*7)	1: Inactive 2: Active 3: Active fast (for M1R only)	_	RD
InternalActivity	MI[100]	Internal status	1: None 2: – 3: Adaption 4: Synchronisation	-	RD

# TRO



RI	121	
DU		11

Object Name	Object Type	Description	Values	COV Increment	Acces
StatusSensor	MI[103]	Status of the differential pressure sensor If status end = automatic reset	1: OK 2: dP sensor not OK 3: dP sensor outside of measuring range 4: dP sensor incorrectly	-	RD
			connected		
StatusFlow	MI[104]	Volume flow rate status If there is no volume flow rate within 600 s, then StatusFlow MI[104] = 3.	1: OK 2: – 3: No airflow detected	-	RD
StatusActuator	MI[106]	Status of the actuator <u>Status flags:</u> (*2)	1: OK 2: Actuator cannot be moved 3: Gear release active 4: Mechanical travel exceeded 5: Actuator not suitable for application	-	RD
StatusPressure	MI[109]	Differential pressure status If the differential pressure is not reached within 180 s, then StatusPressure MI[109] = 3.	1: OK 2: – 3: Pressure not reached	-	RD
StatusDevice	MI[110]	Status of the device during bus monitoring According to BusWatchdog AV[130].	1: OK 2: Bus timeout monitoring activated	-	RD
Override	MO[1]	Override control Overwrites the setpoint value with a forced command. <u>Status flags:</u> (*8)	1: None 2: OPEN 3: CLOSED 4: q <sub>vmin</sub> /∆pmin 5: – 6: q <sub>vmax</sub> /∆pmax Factory setting: None (1)	-	С
ApplicationSel	MV[2]	Display of application VRU-D3-M/B TR, VRU-M1-M/B TR - Flow control - Pressure control - Flow measurement VRU-M1R-M/B TR - Room pressure control	1: Flow control 2: Pressure control 3: Room pressure control 4: Flow measurement	-	RD
ControlMode	MV[100]	Control mode Status flags: (*9)	1: PosCtrl 2: FlowCtrl Factory setting: FlowCtrl	-	RD
OperationMode	MV[102]	Operating mode Only relevant for VRU-M1R-BAC. <u>Status flags:</u> (*10)	1: Negative pressure 2: Positive pressure	-	WR
Command	MV[120]	Release test functions <u>Status flags:</u> (*2)	1: None 2: Adaption 3: – 4: Reset Factory setting: None	-	WR
UnitSelAirFlow	MV[121]	Selection of the volume flow unit	1: - 2: m³/h	_	WR



Object Name	Object Type	Description	Values	COV Increment	Access
		The selected unit is indicated in AI[19] and AV[104]	4: – 5: – 6: – 7: cfm		
SpSource	MV[122]	Selection of the setpoint value setting If SpSource MV[122] = 1 (analogue), then SpAnalog Al[6] = active. If SpSource MV[122] = 2 (bus), then SpRel AO [1] = active.	MP-Bus)	_	WR
UnitSelPressure	MV[127]	Selection of the pressure unit The selected unit is indicated in DeltaP_UnitSel AI[18] and DeltaPnom_UnitSel AV[129].	1: Pascal 3: Water column Factory setting: pascal	-	WR
UnitSelTemp	MV[128]	Selection of temperature unit The selected unit is located in AI[20].	1: K 2: °C 3: °F Factory setting: °C (2)	-	W
Sens1Type	MV[220]	Definition of the sensor type If Sens1Type MV[220] = 2 (active) or 3 (passive), then Sens1Analog AI[20] active. If Sens1Type MV [220] = 5 (switch), then Sens1Schalter BI[20] active.	1: None 2: Active sensor (in hybrid mode) 3: Passive sensor 4: – 5: Switch Factory setting: None	-	WR

RD = Read-only access

WR = Read/write access

C = Commendable with priority array

Status flags:

(\*1) If gear disengagement pressed, then Overridden = 1

(\*2) If ApplicationSel MV[2] = 3 (room pressure control) or 4 (flow measurement), then Out of Service = 1

(\*3) If SpSource MV[122] = 2 (bus), then Out of Service = 1

(\*4) If ApplicationSel MV[2] = 2 (pressure control) or 3 (room pressure control), then Out of Service = 1

(\*5) If Sens1Type MV[220] = 1 (none), then Out of Service = 1

(\*6) If Sens1Type MV[220] ≠ 5, then Out of Service = 1

(\*7) If ApplicationSel MV[2] = 2 (pressure control) or 4 (flow measurement), then Out of Service = 1

(\*8) If ApplicationSel MV[2] = 4 (flow measurement), then Out of Service = 1

(\*9) If ApplicationSel MV[2] ≠ 1 (flow rate control), then Out of Service = 1

(\*10) If ApplicationSel MV[2]  $\neq$  3 (room pressure control), then Out of Service = 1



### **Product details**

### Analogue interface 0 – 10 V DC or 2 – 10 V DC

In the delivery state, the setpoint must be specified via the analogue interface. If the setpoint value is specified via a digital communication interface, this can be changed to Modbus, BACnet or MP-Bus at any time via the TROX FlowCheck App. The analogue interface can be set for the signal voltage range 0 - 10 V DC or 2 - 10 V DC through the TROX FlowCheck App. The assignment of the volume flow setpoint or actual value to the voltage signal is shown in the characteristic diagrams.

### Setpoint value setting

Variable operation

- In the variable operating mode, the setpoint is specified with an analogue signal at terminal 3. Setpoint specifications via the respective bus system are rejected
- The selected signal voltage range 0 10 V or 2 10 V DC is assigned to the volume flow rate range q<sub>vmin</sub> q<sub>vmax</sub> assigned to
- Volume flow rate range  $q_{vmin} q_{vmax}$  set at the factory according to the order code details
- Subsequent adjustment of q<sub>vmin</sub> or q<sub>vmax</sub> possible via adjustment device, TROX FlowCheck app or PC tool Constant value mode
- In the operating mode fixed value operation, no analogue signal is required at terminal 3
- The value given by q<sub>vmin</sub> is controlled through the fixed volume flow rate value
- Volume flow q<sub>vmin</sub> set at the factory according to the order code details
- Subsequent adjustment of q<sub>vmin</sub> possible via adjustment device, TROX FlowCheck app or PC tool

### Actual value as feedback for monitoring or tracking control

- The actual volume flow rate measured by the controller can be captured as a voltage signal at terminal 5
- Selected signal voltage range 0 10 V DC or 2 10 V DC is applied to the volume flow range 0 q<sub>vnom</sub> shown
- In analogue mode, there is the parallel option of querying operating data via the Modbus interface (hybrid mode)

### **Override control**

For special operating situations, the volume flow controller can be set to a special operating state (override control). The following modes are possible: control  $q_{vmin}$ , control  $q_{vmax}$ , damper blade open (OPEN), damper blade closed (CLOSED) or control stop.

### Override controls via signal input Y or override control inputs z1, z2

Through suitable wiring of the inputs Y, z1, z2, the override controls can be activated according to the wiring diagrams via wiring with external switching contacts/relays (see wiring examples).

### Override control CLOSED via command signal at signal input Y

- With signal voltage range 0 10 V DC and setting value  $q_{vmin} = 0$
- Flap CLOSED: Y < 0.45 V DC</li>
- Modulating duty: Y > 0.55 V DC
- With signal voltage range 0 10 V DC and  $q_{vmin} > 0$
- If override control CLOSED is not possible via the command signal. The control process takes place over the entire signal voltage range

With signal voltage range 2 - 10 V DC and setting value q<sub>vmin</sub> = 0

- Flap CLOSED: Y < 2.36 V DC</li>
- Modulating duty: Y > 2.44 V DC
- With signal voltage range 2 10 V DC and setting value  $q_{vmin} > 0$
- Flap CLOSED: Y < 0.3 V DC
- Regulation q<sub>vmin</sub>: Y > 0.3 V DC
- Modulating duty: Y > 2.44 V DC





For a setpoint value specification via the bus interface, an on-site conversion with the TROX FlowCheck App is necessary. The bus interface can be set to Modbus, BACnet and MP-Bus. For smooth data exchange in the on-site bus network, it is necessary to set the communication parameters and the participant address for the bus interface. The communication parameters of the bus systems (address, baud rate, etc.) can be set using the TROX FlowCheck app. The interface provides standardised bus register/object access to the available data points.

### Setpoint value setting

- In Modbus RTU operating mode (factory setting), the setpoint is specified by entering the volume flow setpoint [%] in Modbus register 0
- In the BACnet MS/TP operating mode, the setpoint is specified by specifying the volume flow setpoint [%] in the BACnet object AI[1]
- The percentage value refers to the volume flow rate range specified by q<sub>vmin</sub> q<sub>vmax</sub> defined volume flow range
- Volume flow rate range q<sub>vmin</sub> q<sub>vmax</sub> set at the factory according to the order code details
- Subsequent adjustment of q<sub>vmin</sub> or q<sub>vmax</sub> possible via setting device, TROX FlowCheck App, PC tool or via Modbus/BACnet interface

### Actual value as feedback for monitoring or tracking control

- Both Modbus and BACnet show actual values in m<sup>3</sup>/h (factory setting). Other units such as I/s and cfm can also be selected.
- In addition to the volume flow rate actual value, other information can be read out using other Modbus registers/BACnet objects
- Overview of the registers/objects in the communication tables
- In bus mode the actual volume flow rate can be captured at terminal 5
- The volume flow rate range 0 q<sub>vnom</sub> always corresponds to the signal voltage range (0)2 10 V DC

### Override control

For special operating situations, the volume flow controller can be set to a special operating state (override control). The following modes are possible: control  $q_{vmin}$ , control  $q_{vmax}$  the control damper is in the open position (OPEN), control damper closed (CLOSED) or control stop.

### Priority control via the bus

Specifications are made via Modbus register 1 or via BACnet object type MO[1].

### Override control by bus failure monitoring (Modbus)

In case of failure of the Modbus communication for a defined period of time, a predefined operating state  $q_{vmin}$ ,  $q_{vmax}$ , OPEN or CLOSED can be activated.

- The override to be activated in case of bus failure is defined via Modbus register 108 or 109
- The determination after which bus failure time the override control is activated is made via Modbus register 109 or 110
- Any Modbus communication resets the bus failure monitoring timeout

### Override control by bus failure monitoring (BACnet)

If BACnet communication fails for a specified period of time, a predefined operating state can be activated.

- The setpoint to be activated in the event of bus failure is determined via the Reliquish\_Default of SpRel (Object AO1)
- Bus failure time is defined via BusWatchdog (object type AV [130])
- · Communication on the data points SpRel (Object AO[1] and Override (Object MO[1]) resets the timeout of bus failure monitoring

### **Override controls for diagnosis**

Activation via bus systems, external/on-site switching contacts (bridges), and TROX FlowCheck App.


### Prioritisation of different default options

Specifications for override controls via switching contacts are prioritised over Modbus/BACnet specifications.

- Highest priority: Preset via override control by external wiring (switching contact, relay)
- Medium priority: Specifications via the service plug (TROX FlowCheck App) for test purposes
- Lowest priority: Default via Modbus/BACnet/MP bus

# TRO

### Characteristic of the setpoint value signal




- ① Signal voltage range 0 10 V
- ② Signal voltage range 2 10 V
- $1^* = q_{vnom}$  Nominal volume flow rate
- 2\* = q<sub>vmin unit</sub> Acceptable minimum volume flow rate

Calculation of volume flow rate setpoint value at 0 – 10 V

$$q_{vset} = \frac{Y}{10 V} \times (q_{vmax} - q_{vmin}) + q_{vmin}$$





- ① Signal voltage range 0 10 V
- ② Signal voltage range 2 10 V
- $1^* = q_{vnom}$  Nominal volume flow rate
- $2^* = q_{vmin unit}$  Acceptable minimum volume flow rate

Calculation of volume flow rate actual value at 0 – 10 V

$$q_{vact} = \frac{U}{10 V} \times q_{vnom}$$

Calculation of volume flow rate setpoint value at 2 – 10 V


Calculation of volume flow rate actual value at 2 – 10 V


$$q_{set} = \frac{Y - 2V}{(10V - 2V)} \times (q_{vmax} - q_{vmin}) + q_{vmin}$$

$$q_{vact} = \frac{U-2}{10 V - 2 V} \times q_{vnom}$$



### View of plug-in terminal strips at the VRU





Universal

#### Nomenclature


- 1, 6, 9, 13:  $\perp$ , = Ground, neutral
- 2, 10, 14: ~, + = Supply voltage 24 V
- 3: Y = Setpoint signal Y and override controls
- 5: U/MP = Actual value signal or MP-Bus or service tool connection
- 7: D+ = B = C2 = RS-485 bus (BACnet MS/TP or Modbus RTU)
- 8: D- = A = C1 = RS-485 bus (BACnet MS/TP or Modbus RTU)
- 11, 12: z1, z2 = Forced control inputs
- 15: Extension for external sensor
- 16: Not used



# **TRO**<sup>®</sup>теснык



### Wiring diagram analogue control



### Nomenclature

1:  $\perp$ , – = Ground, neutral


- 2: ~, + = Supply voltage 24 V AC/DC
- 3: Y = Setpoint signal and override controls
- 5: U/MP = Actual value signal

### Notes

- T, VOC, CO2, DDC = Setpoint value default setting q<sub>v</sub>
- Setpoint value and actual value signals depend on the signal voltage range, either 0 10 V DC or 2 10 V DC



### Wiring diagram Modbus, BACnet operation



#### Nomenclature

1: ⊥, – = Ground, neutral

2: ~, + = Supply voltage 24 V AC/DC

6: GND = Common ground potential


7: D+ = Modbus/BACnet B, C2

8: D- = Modbus/BACnet A, C1

### Note

- ① Additional network participants for Modbus/BACnet (maximum 32)
- Supply voltage and communication not galvanically isolated
- · Voltage supply: Make sure that all devices on the bus have the same GND reference point
- Use terminal resistors on both ends of the bus. Bus terminating resistors integrated in the VRU can be activated with the service tool





### Nomenclature

1:  $\bot$ , - = Ground, neutral 2: ~, + = Supply voltage 24 V AC/DC


5: U/MP = MP-Bus connection

**TROX**<sup>®</sup>теснык

### Note

- ① Number of MP-Bus participants depends on the type of MP-Bus devices; maximum 16 participants
- Of which max. 8 MP participants (e.g. volume flow controller)
- Plus a maximum of 8 MPL participants (e.g. valve drives)
- Supply voltage and communication not galvanically isolated
- · Voltage supply: Make sure that all devices on the bus have the same GND reference point.

### Connection diagram hybrid operation



#### Nomenclature:

1: ⊥, – = Ground, neutral

2: ~, + = Supply voltage 24V AC/DC

6: GND = Common ground potential

7: D+ = Modbus/BACnet B, C2

8: D- = Modbus/BACnet A, C1


### Notes

- T, VOC, CO 2, DDC = Setpoint q<sub>v</sub>
- ① Additional network participants for Modbus/BACnet (maximum 32)
- Supply voltage and communication not galvanically isolated
- Voltage supply: Make sure that all devices on the bus have the same GND reference point.
- Use bus terminating resistors at the ends of the bus line
- Bus terminating resistors integrated in the VRU can be activated with the service tool





## Connection diagram for override controls, Alternative 1: Y-input



### Nomenclature

1:  $\perp$ , – = Ground, neutral

- 2: ~, + = Supply voltage 24 V AC/DC
- 3: Y = Setpoint signal and override controls
- 5: U/MP = Actual value signal or MP-Bus or service tool connection

### Notes

- T, VOC, CO2, DDC = setpoint for q<sub>v</sub>
- When combining several override controls, the switches must be interlocked to prevent short-circuits
- Setpoint value and actual value signals depend on the signal voltage range, either 0 10 V DC or 2 10 V DC
- Supply voltage and communication not galvanically isolated
- Voltage supply: Make sure that all devices on the bus have the same GND reference point
- Use terminal resistors on both ends of the bus. Bus terminating resistors integrated in the VRU can be activated with the service tool

### Wiring variants Y-signal

### Constant value mode q<sub>vmin</sub> (override control q<sub>vmin</sub>)

- Only switch (connection) S1 may be closed
- Only works with signal voltage range 0 10 V DC

### Override control q<sub>vmax</sub>

Only S2 has to be closed

### Normal operation q<sub>vmin</sub> - q<sub>vmax</sub>

- Analogue setpoint setting e.g. by room temperature control
- Only S3 has to be closed


### Override control, damper blade CLOSED

- Only S1 has to be closed
- Only works with signal voltage range 2 10 V DC





### Connection diagram for override controls, Alternative 2: z1/z2 input



### Nomenclature

9: ⊥, – = Ground, neutral

10: ~, + = Supply voltage 24 V AC/DC

11: Priority z1

12: Priority z2

13:  $\perp$ , – = Ground, neutral

14: ~, + = Supply voltage 24 V AC/DC

### Notes

- When combining several override controls, the switches must be interlocked to prevent short-circuits
- Setpoint value and actual value signals depend on the signal voltage range, either 0 10 V DC or 2 10 V DC
- Supply voltage and communication not galvanically isolated
- Voltage supply: Make sure that all devices on the bus have the same GND reference point.

 Use terminal resistors on both ends of the bus. Bus terminating resistors integrated in the VRU can be activated with the service tool

### Wiring variants z1/z2 input

### Override control, damper blade OPEN

Only S2 has to be closed

### Override control, damper blade CLOSED

Only S3 has to be closed

### Override control q<sub>vmax</sub>

Only S4 has to be closed

### Control stop

Only S1 has to be closed

Further override controls possible at the Y input.





### **Explanation**

### **q**<sub>vNom</sub> [m3/h]; [l/s]; [CFM]

Nominal flow rate (100 %): The value depends on product type, nominal size and control component (attachment). Values are published on the internet and in technical leaflets and defined in the Easy Product Finder design programme. Reference value for calculating percentages (e.g.  $q_{vmax}$ ). Upper limit of the setting range and maximum volume flow rate setpoint value for the VAV terminal unit.

### q<sub>vmin Unit</sub> [m3/h]; [l/s]; [CFM]

Technical minimum volume flow: The value depends on product type, nominal size and control component (attachment). Values are defined in the Easy Product Finder design programme Lower limit of the setting range and minimum volume flow rate setpoint value for the VAV terminal unit. Setpoint values below  $q_{vmin}$  unit, (if  $q_{vmin}$  equals zero) may result in unstable control or shut-off.

### q<sub>vmax</sub> [m3/h]; [l/s]; [CFM]

Client-adjustable upper limit of the operating range for the VAV terminal unit:  $q_{vmax.}$  can be set to less than or equal to  $q_{vNom}$  on the terminal unit. In case of analogue control of volume flow controllers (typically used), the maximum value of the setpoint signal (10 V) is assigned to the set maximum value ( $q_{vmax.}$ , see characteristics.

### q<sub>vmin</sub> [m3/h]; [l/s]; [CFM]

Client-adjustable lower limit of the operating range of the VAV terminal unit:  $q_{vmin}$  should be set to less than or equal to  $q_{vmax}$ .  $q_{vmin}$  must not be set to less than  $q_{vmin unit}$  as the control may become unstable or the damper blade may close.  $q_{vmin}$  may equal zero. In case of analogue control of volume flow controllers (typically

used), the minimum value of the setpoint signal (0 or 2 V) is assigned to the set minimum value  $(q_{vmin})$  see characteristics.

**q**<sub>v</sub> [m3/h]; [l/s]; [CFM] Volume flow rate

### Volume flow controller

Consists of a basic unit with an attached control component.

### **Basic unit**

Unit for controlling volume flow rates without an attached control component. The main components include the casing with sensor(s) to measure the differential pressure and the damper blade to restrict the volume flow. The basic unit is also referred to as a VAV terminal unit. Important distinguishing features: Geometry or unit shape, material and connection variants, acoustic characteristics (e.g. optional acoustic cladding or integrated silencers), range of volume flow.

### **Control component**

Electronic unit(s) mounted on the basic unit to control the volume flow rate, or the duct pressure, or the room pressure by adjusting the damper blade position. The electronic unit mainly consists of a controller with differential pressure transducer (integrated or external), and an integrated actuator (Easy and Compact controllers) or external actuator (Universal or LABCONTROL controller). Important distinguishing features: Transducer: dynamic transducer for clean air, or static transducer for polluted air. Actuator: Standard actuator (slow-running), spring return actuator for fail-safe position, or fast-running actuator. Interface technology: analogue interface or digital bus interface for connecting and recording signals and data.